


STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**  
MISSOURI CLEAN WATER COMMISSION



**MISSOURI STATE OPERATING PERMIT**

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No.: MO-0046078

Owner: City of Rock Port, Board of Public Works  
Address: 102 West Clay, Rock Port, MO 64482

Continuing Authority: Same as above  
Address: Same as above

Facility Name: Rock Port Wastewater Treatment Facility  
Address: Rock Port, MO 64482

Legal Description: SE ¼, SW ¼, Sec. 34, T65N, R41W, Atchison County

Receiving Stream: Rock Creek (C)  
First Classified Stream and ID: Rock Creek (C) (00237)  
USGS Basin & Sub-watershed No.: (10240005-050003)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

**FACILITY DESCRIPTION**

Outfall #001 - POTW - SIC #4952  
Three cell lagoon/sludge disposal is by contract hauler.  
Design population equivalent is 2,100.  
Design flow is 210,000 gallons per day.  
Actual flow is 10,000 gallons per day.  
Design sludge production is 14.7 dry tons/year.  
Actual sludge production is 7 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

July 14, 2006  
Effective Date

  
Doyle Childers, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

July 13, 2011  
Expiration Date  
MO 780-0041 (10-93)

  
Karl Fett, Director, Kansas City Regional Office

## PERMIT NUMBER MO-0046078

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective upon issuance and remain in effect until three (3) years from the date of issuance of this permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/month	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub> **	mg/L		65	45	once/month	24 hr. modified composite****
Total Suspended Solids**	mg/L		100	70	once/month	24 hr. modified composite****
pH – Units	SU	***		***	once/month	grab
Ammonia as N	mg/L	*		*	once/month	grab
Oil & Grease	mg/L	15		10	once/month	grab
Temperature	<sup>0</sup> C	*		*	once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED MONTHLY; THE FIRST REPORT IS DUE August 28, 2006. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- ```
* Monitoring requirement only.
** This facility is required to meet a removal efficiency of 65% or more.
*** pH is measured in pH units and is not to be averaged. The pH is to be maintained at
    or above 6.0 pH units.
**** A composite sample made up from a minimum of 4 grab samples collected within a 24
    hour period with a minimum of two hours between each grab.
```

|                                                                                                                                                                                                                                                                                                                                                                                                     |          |                            |                   |                    |                          | PAGE NUMBER 3 of 6               |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|----------------------------|-------------------|--------------------|--------------------------|----------------------------------|--|
| <b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>                                                                                                                                                                                                                                                                                                                                          |          |                            |                   |                    |                          | PERMIT NUMBER MO-0046078         |  |
|                                                                                                                                                                                                                                                                                                                                                                                                     |          |                            |                   |                    |                          |                                  |  |
| The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective three (3) years from the date of issuance of this permit and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below: |          |                            |                   |                    |                          |                                  |  |
| OUTFALL NUMBER AND EFFLUENT<br>PARAMETER(S)                                                                                                                                                                                                                                                                                                                                                         | UNITS    | FINAL EFFLUENT LIMITATIONS |                   |                    | MONITORING REQUIREMENTS  |                                  |  |
|                                                                                                                                                                                                                                                                                                                                                                                                     |          | DAILY<br>MAXIMUM           | WEEKLY<br>AVERAGE | MONTHLY<br>AVERAGE | MEASUREMENT<br>FREQUENCY | SAMPLE<br>TYPE                   |  |
| <u>Outfall #001</u>                                                                                                                                                                                                                                                                                                                                                                                 |          |                            |                   |                    |                          |                                  |  |
| Flow                                                                                                                                                                                                                                                                                                                                                                                                | MGD      | *                          |                   | *                  | once/month               | 24 hr.<br>estimate               |  |
| Biochemical Oxygen Demand <sub>5</sub> **                                                                                                                                                                                                                                                                                                                                                           | mg/L     |                            | 65                | 45                 | once/month               | 24 hr. modified<br>composite**** |  |
| Total Suspended Solids**                                                                                                                                                                                                                                                                                                                                                                            | mg/L     |                            | 100               | 70                 | once/month               | 24 hr. modified<br>composite**** |  |
| pH – Units                                                                                                                                                                                                                                                                                                                                                                                          | SU       | ***                        |                   | ***                | once/month               | grab                             |  |
| Ammonia as N<br>(May 1 – Oct 31)                                                                                                                                                                                                                                                                                                                                                                    | mg/L     | 3.7                        |                   | 1.9                | once/month               | grab                             |  |
| Ammonia as N<br>(Nov 1 – April 30)                                                                                                                                                                                                                                                                                                                                                                  | mg/L     | 7.5                        |                   | 3.7                | once/month               | grab                             |  |
| Temperature                                                                                                                                                                                                                                                                                                                                                                                         | °C       | *                          |                   | *                  | once/month               | grab                             |  |
| Oil & Grease                                                                                                                                                                                                                                                                                                                                                                                        | mg/L     | 15                         |                   | 10                 | once/month               | grab                             |  |
| Fecal Coliform                                                                                                                                                                                                                                                                                                                                                                                      | #/100 mL | 1000                       |                   | 400                | once/month               | grab                             |  |
| Total Residual Chlorine (Note 1)                                                                                                                                                                                                                                                                                                                                                                    | mg/L     | 0.019                      |                   | 0.01               | once/month               | grab                             |  |
| MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>August 28, 2009</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.                                                                                                                                                                                                 |          |                            |                   |                    |                          |                                  |  |
| <b>B. STANDARD CONDITIONS</b>                                                                                                                                                                                                                                                                                                                                                                       |          |                            |                   |                    |                          |                                  |  |
| IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.                                                                                                                                             |          |                            |                   |                    |                          |                                  |  |

MO 780-0010 (8/91)

**B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)**

- \* Monitoring requirement only.
- \*\* This facility is required to meet a removal efficiency of 65% or more.
- \*\*\* pH is measured in pH units and is not to be averaged. The pH is to be maintained at or above 6.0 pH units.
- \*\*\*\* A composite sample made up from a minimum of 4 grab samples collected within a 24 hour period with a minimum of two hours between each grab.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

Note 1 - This permit contains a Total Residual Chlorine (TRC) limit.

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500 - CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- (b) Disinfection is required year-round unless the permit specifically states that "Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31." If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.
- (c) Do not chemically dechlorinate **if it is not needed to meet the limits in your permit.**
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as "0 mg/L" TRC.

C. SPECIAL CONDITIONS

- 1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
- 2. All outfalls must be clearly marked in the field.

C. SPECIAL CONDITIONS (continued)

3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.

4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
  - (1) One hundred micrograms per liter (100 µg/L);
  - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
  - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
- (c) That the effluent limit established in part A of the permit will be exceeded.

5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards.

- a. Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- b. General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
  - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
  - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
  - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
  - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
  - (5) There shall be no significant human health hazard from incidental contact with the water;
  - (6) There shall be no acute toxicity to livestock or wildlife watering;
  - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
  - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

C. SPECIAL CONDITIONS (continued)

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
  - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.